island health

DRINKING WATER SYSTEM ANNUAL REPORT

Reporting Period: January 1st to December 31st , 2017 (year)

Water System Shawnigan Lakle North Water System

Water System Owner Cowichan Valley Regional District

Primary Contact Name (Operator or Manager) Brian Dennison

Phone Number (Operator or Manager) 250-746-2532

E-mail (Operator or Manager) bdennsion@cvrd.bc.ca

DESCRIBE YOUR WATER SUPPLY SYSTEM

What is the Source(s) of Raw Water?

☒ Deep Well ☐ Shallow Well ☒ Surface Water ☐ Other

If other, specify details:

Does the Drinking Water System have Primary Disinfection? ☒ Yes ☐ No

☒ Chlorination ☐ Ultraviolet Light ☐ Ozone ☐ Other

If other, specify details:

Does the Drinking Water System have Secondary Disinfection? ☐ Yes ☒ No

☐ Chlorination ☐ Other

If other, specify details:

Does the Drinking Water System have Filtration? ☒ Yes ☐ No

Check all boxes that apply

☐ Cartridge Filter(s) ☐ Carbon Filter ☐ Sand Filtration ☐ Reverse Osmosis ☒ Other

If other, specify details:

PUBLIC REPORTING

Emergency Response & Contingency Plan (ERCP)

Is your ERCP up to Date? ☐ Yes ☒ No

How do you Inform the System Users of the ERCP?

☐ Hand Delivered ☐ Bulletin Board ☐ Newspaper ☐ Utility Bill Insert ☐ Website

☒ Other (specify details) CVRD Engineering Services, 175 Ingram Street, Duncan, BC

Drinking Water System Annual Report

How do you Inform the System Users of the Annual Report?

☐ Hand Delivered ☐ Bulletin Board ☐ Newspaper ☐ Utility Bill Insert ☒ Website

☐ Other (specify details)

COMPLIANCE WITH OPERATING PERMIT

List the conditions of your Operating Permit (Contact the DWO for a copy if needed):

Turbidity monitoring and produce water with less than 1 NTU

4-log removal/inactivation of viruses

3-log removal/inactivation of Giardia cysts and Cryptosporidium oocysts

Are you in compliance with your Operating Permit? ☒ Yes ☐ No

BACTERIOLOGICAL TESTING AND DRINKING WATER PROTECTION REGULATION WATER QUALITY STANDARDS

How many bacteriological samples were collected during this reporting period? 99

What is the minimum required sampling frequency for this system? (#samples/month) 4 samples/month

Additional sampling details:

Was the minimum required sampling frequency achieved? ☒ Yes ☐ No

Comments:

Bacteriological summary attached to this report? ☒ Yes ☐ No

If no, how do the users of the system view the results?

WATER QUALITY STANDARDS FOR POTABLE WATER

Parameter:	***Standard:***	**Did this system meet standard?**	
Escherichia coli (for all samples)	No detectable *Escherichia coli* per 100ml	☒ Yes	☐ No
Total Coliform Bacteria *(if only 1 sample collected in a 30 day period)*	No detectable total coliform bacteria per 100ml	☒ Yes	☐ No
Total Coliform Bacteria *(if more than 1 sample collected in a 30 day period)*	No more than 10% of samples contain total coliform bacteria, **and** No sample has more than 10 total coliform bacteria per 100ml	☒ Yes	☐ No

If the system did not meet any of above Drinking Water Protection Regulation standards, record the results in the table below; attach additional sheets if necessary.

Date	TC/100ml	E.coli/100ml	Reason	Corrective Action

CHEMICAL SAMPLING COMPLETED DURING THIS REPORTING PERIOD

Was any chemical sampling conducted during reporting period?	■ Yes	☐ No
If no, when were the last chemical samples conducted for this system? (date)		☐ Don't know
If yes, attach a list of the chemical results See attached full spectrum report		
If any water samples did not meet the Guidelines for Canadian Drinking Water Quality, record the results in the table below; attach additional sheets if necessary.		
Next scheduled full chemical test (date) July, 2018		

Parameter	Result	Corrective Action / Treatment / Comments

ADDITIONAL TESTING

Does the system have analyzers for continuous monitoring? ■ Yes ☐ No

If yes, check all boxes that apply:

■ Chlorine ■ Turbidity ☐ Other (details)

Are the results available on request?

If any additional testing or sampling was conducted, record results in the table below; attach additional sheets if necessary.

Additional Testing & Reason for Sampling	Corrective Action Taken

WATER QUALITY COMPLAINTS

Were there any water quality complaints in this reporting period? (e.g. taste, odour, colour etc.) ■ Yes ☐ No

If yes, complete the table below; attach additional sheets if necessary.

Date	Water Quality Complaint	Corrective Action / Treatment
May 12/17	Rusty taste	Lake Turning
May 15/17	Bad taste and odorous	Lake Turning
June 6/17	Bad taste and odorous	Lake Turning

island health

OPERATIONAL PROBLEMS

Were there any operational problems during this reporting period? (e.g. insufficient water supply, malfunction of disinfection equipment, line breaks, elevated turbidity etc.). ☐ Yes ☒ No

If yes, complete the table below; attach additional sheets if necessary.

Incident Date	Type of Operational Problem	Corrective Action Taken

MAJOR UPGRADES/REPAIRS & EXPENSES

Were there any major upgrades/repairs or any major costs incurred during this reporting period? ☐ Yes ☒ No

If yes, complete the table below; attach additional sheets if necessary.

Major Upgrades/Expenses	Details
Improvements required by DWO	
Additions/changes to system	
Purchase or install new equipment	
Equipment repair or replacement	
Annual maintenance of system	System flushing, hydrant maintenance
Specialist report	
Other	

FUTURE IMPROVEMENTS

Are there any plans for future improvements? ☐ Yes ☒ No

If yes, complete the table below; attach additional sheets if necessary.

Future Upgrades or Improvements	Estimated Date of Completion

Click here to enter a date. May-2018 **DATE COMPLETED:**	Rod Lama **COMPLETED BY:**

Alkalinity (bicarbonate, as CaCO3)			Sampling Point Name
05/04/2017 12:20	77.5	mg/L	S1-2209 McKean Rd

Alkalinity (carbonate, as CaCO3)			Sampling Point Name
05/04/2017 12:20	< 1.0	mg/L	S1-2209 McKean Rd

Alkalinity (hydroxide, as CaCO3)			Sampling Point Name
05/04/2017 12:20	< 1.0	mg/L	S1-2209 McKean Rd

Alkalinity (total, as CaCO3)			Sampling Point Name
05/04/2017 12:20	77.5	mg/L	S1-2209 McKean Rd

Aluminum (total)			Sampling Point Name
05/04/2017 12:20	0.020	mg/L	S1-2209 McKean Rd

Ammonia (total, as N)			Sampling Point Name
05/04/2017 12:20	< 0.0050	mg/L	S1-2209 McKean Rd

Antimony (total)			Sampling Point Name
05/04/2017 12:20	< 0.00050	mg/L	S1-2209 McKean Rd

Arsenic (total)			Sampling Point Name
05/04/2017 12:20	0.00089	mg/L	S1-2209 McKean Rd

Background Bacteria			Sampling Point Name
05/04/2017 12:20	< 1	CFU/100ml	S1-2209 McKean Rd

Barium (total)			Sampling Point Name
05/04/2017 12:20	0.055	mg/L	S1-2209 McKean Rd

Beryllium (total)			Sampling Point Name
05/04/2017 12:20	< 0.0050	mg/L	S1-2209 McKean Rd

Bismuth (total)			Sampling Point Name
05/04/2017 12:20	< 0.20	mg/L	S1-2209 McKean Rd

Boron (total)			Sampling Point Name
05/04/2017 12:20	< 0.10	mg/L	S1-2209 McKean Rd

Bromide			Sampling Point Name
05/04/2017 12:20	< 0.050	mg/L	S1-2209 McKean Rd

Bromochloroacetic acid			Sampling Point Name
02/22/2017 12:42	0.0017	mg/L	S1-2209 McKean Rd
05/04/2017 12:20	0.0029	mg/L	S1-2209 McKean Rd

Bromochloroacetic acid			Sampling Point Name
08/16/2017 00:00	0.0028	mg/L	S1-2209 McKean Rd
11/09/2017 09:45	0.0011	mg/L	S1-2209 McKean Rd

Bromodichloromethane			Sampling Point Name
02/22/2017 12:42	0.0015	mg/L	S1-2209 McKean Rd
05/04/2017 12:20	0.0043	mg/L	S1-2209 McKean Rd
08/16/2017 00:00	0.0043	mg/L	S1-2209 McKean Rd
11/09/2017 09:45	0.0047	mg/L	S1-2209 McKean Rd

Bromoform			Sampling Point Name
02/22/2017 12:42	< 0.0010	mg/L	S1-2209 McKean Rd
05/04/2017 12:20	< 0.0010	mg/L	S1-2209 McKean Rd
08/16/2017 00:00	< 0.0010	mg/L	S1-2209 McKean Rd
11/09/2017 09:45	< 0.0010	mg/L	S1-2209 McKean Rd

Cadmium (total)			Sampling Point Name
05/04/2017 12:20	< 0.00020	mg/L	S1-2209 McKean Rd

Calcium (total)			Sampling Point Name
05/04/2017 12:20	26.6	mg/L	S1-2209 McKean Rd

Chloride			Sampling Point Name
05/04/2017 12:20	8.99	mg/L	S1-2209 McKean Rd

Chloroform			Sampling Point Name
02/22/2017 12:42	0.0473	mg/L	S1-2209 McKean Rd
05/04/2017 12:20	0.0658	mg/L	S1-2209 McKean Rd
08/16/2017 00:00	0.0710	mg/L	S1-2209 McKean Rd
11/09/2017 09:45	0.0716	mg/L	S1-2209 McKean Rd

Chromium (total)			Sampling Point Name
05/04/2017 12:20	< 0.0020	mg/L	S1-2209 McKean Rd

Cobalt (total)			Sampling Point Name
05/04/2017 12:20	< 0.010	mg/L	S1-2209 McKean Rd

Colour			Sampling Point Name
05/04/2017 12:20	< 5.0	TCU	S1-2209 McKean Rd

Conductivity			Sampling Point Name
05/04/2017 12:20	204	uS/cm	S1-2209 McKean Rd

Copper (total)			Sampling Point Name
05/04/2017 12:20	0.0184	mg/L	S1-2209 McKean Rd

Dibromoacetic acid			Sampling Point Name
02/22/2017 12:42	< 0.0010	mg/L	S1-2209 McKean Rd
05/04/2017 12:20	0.0018	mg/L	S1-2209 McKean Rd
08/16/2017 00:00	< 0.0010	mg/L	S1-2209 McKean Rd
11/09/2017 09:45	< 0.0010	mg/L	S1-2209 McKean Rd

Dibromochloromethane			Sampling Point Name
02/22/2017 12:42	< 0.0010	mg/L	S1-2209 McKean Rd
05/04/2017 12:20	< 0.0010	mg/L	S1-2209 McKean Rd
08/16/2017 00:00	< 0.0010	mg/L	S1-2209 McKean Rd
11/09/2017 09:45	< 0.0010	mg/L	S1-2209 McKean Rd

Dichloroacetic acid			Sampling Point Name
02/22/2017 12:42	0.0197	mg/L	S1-2209 McKean Rd
05/04/2017 12:20	0.0276	mg/L	S1-2209 McKean Rd
08/16/2017 00:00	0.0262	mg/L	S1-2209 McKean Rd
11/09/2017 09:45	0.0136	mg/L	S1-2209 McKean Rd

Escherichia coli / E. coli (counts)			Sampling Point Name
05/04/2017 12:20	< 1	counts/100ml	S1-2209 McKean Rd

Fecal Coliforms (counts)			Sampling Point Name
05/04/2017 12:20	< 1	counts/100ml	S1-2209 McKean Rd

Fluoride			Sampling Point Name
05/04/2017 12:20	0.058	mg/L	S1-2209 McKean Rd

Haloacetic acids 5 / HAA5			Sampling Point Name
02/22/2017 12:42	0.0428	mg/L	S1-2209 McKean Rd
05/04/2017 12:20	0.0762	mg/L	S1-2209 McKean Rd
08/16/2017 00:00	0.0608	mg/L	S1-2209 McKean Rd
11/09/2017 09:45	0.0551	mg/L	S1-2209 McKean Rd

Hardness (total, as CaCO3)			Sampling Point Name
05/04/2017 12:20	79.8	mg/L	S1-2209 McKean Rd

Heterotrophic Plate Count / HPC			Sampling Point Name
05/04/2017 12:20	< 100	CFU/100ml	S1-2209 McKean Rd

Iron (total)			Sampling Point Name
05/04/2017 12:20	< 0.030	mg/L	S1-2209 McKean Rd

Iron Bacteria (MPN / PA)			Sampling Point Name
05/04/2017 12:20	SC		S1-2209 McKean Rd

Langelier Index			Sampling Point Name
05/04/2017 12:20	-0.14		S1-2209 McKean Rd

Langelier Index (@ 20 C)			Sampling Point Name
05/04/2017 12:20	12.8		S1-2209 McKean Rd

Lead (total)			Sampling Point Name
05/04/2017 12:20	0.00106	mg/L	S1-2209 McKean Rd

Lithium (total)			Sampling Point Name
05/04/2017 12:20	< 0.010	mg/L	S1-2209 McKean Rd

Magnesium (total)			Sampling Point Name
05/04/2017 12:20	3.24	mg/L	S1-2209 McKean Rd

Manganese (total)			Sampling Point Name
05/04/2017 12:20	0.0021	mg/L	S1-2209 McKean Rd

Mercury (total)			Sampling Point Name
05/04/2017 12:20	< 0.00020	mg/L	S1-2209 McKean Rd

Molybdenum (total)			Sampling Point Name
05/04/2017 12:20	< 0.030	mg/L	S1-2209 McKean Rd

Monobromoacetic acid			Sampling Point Name
02/22/2017 12:42	< 0.0010	mg/L	S1-2209 McKean Rd
05/04/2017 12:20	< 0.0010	mg/L	S1-2209 McKean Rd
08/16/2017 00:00	< 0.0010	mg/L	S1-2209 McKean Rd
11/09/2017 09:45	< 0.0010	mg/L	S1-2209 McKean Rd

Monochloroacetic acid			Sampling Point Name
02/22/2017 12:42	< 0.0050	mg/L	S1-2209 McKean Rd
05/04/2017 12:20	< 0.0050	mg/L	S1-2209 McKean Rd
08/16/2017 00:00	< 0.0050	mg/L	S1-2209 McKean Rd
11/09/2017 09:45	< 0.0050	mg/L	S1-2209 McKean Rd

Nickel (total)			Sampling Point Name
05/04/2017 12:20	< 0.050	mg/L	S1-2209 McKean Rd

Nitrate (as N)			Sampling Point Name
05/04/2017 12:20	0.386	mg/L	S1-2209 McKean Rd

Nitrate + Nitrite (as N)			Sampling Point Name
05/04/2017 12:20	0.386	mg/L	S1-2209 McKean Rd

Nitrite (as N)			Sampling Point Name
05/04/2017 12:20	< 0.0010	mg/L	S1-2209 McKean Rd

pH			Sampling Point Name
02/22/2017 12:42	7		S1-2209 McKean Rd
05/04/2017 12:20	8.48		S1-2209 McKean Rd
05/04/2017 12:20	8.48		S1-2209 McKean Rd
05/04/2017 12:20	8.01		S1-2209 McKean Rd
08/16/2017 00:00	8.48		S1-2209 McKean Rd

Phosphorus (total)			Sampling Point Name
05/04/2017 12:20	< 0.30	mg/L	S1-2209 McKean Rd

Potassium (total)			Sampling Point Name
05/04/2017 12:20	0.36	mg/L	S1-2209 McKean Rd

Selenium (total)			Sampling Point Name
05/04/2017 12:20	< 0.0010	mg/L	S1-2209 McKean Rd

Silicon (total, as Si)			Sampling Point Name
05/04/2017 12:20	4.62	mg/L	S1-2209 McKean Rd

Silver (total)			Sampling Point Name
05/04/2017 12:20	< 0.010	mg/L	S1-2209 McKean Rd

Sodium (total)			Sampling Point Name
05/04/2017 12:20	9.7	mg/L	S1-2209 McKean Rd

Strontium (total)			Sampling Point Name
05/04/2017 12:20	0.385	mg/L	S1-2209 McKean Rd

Sulfate Reducing Bacteria			Sampling Point Name
05/04/2017 12:20	SC		S1-2209 McKean Rd

Sulphate			Sampling Point Name
05/04/2017 12:20	7.08	mg/L	S1-2209 McKean Rd

Sulphide (total, as S)			Sampling Point Name
05/04/2017 12:20	< 0.018	mg/L	S1-2209 McKean Rd

Tannins and Lignins			Sampling Point Name
05/04/2017 12:20	< 0.10	mg/L	S1-2209 McKean Rd

Thallium (total)			Sampling Point Name
05/04/2017 12:20	< 0.20	mg/L	S1-2209 McKean Rd

Tin (total)			Sampling Point Name
05/04/2017 12:20	< 0.030	mg/L	S1-2209 McKean Rd

Titanium (total)			Sampling Point Name
05/04/2017 12:20	< 0.010	mg/L	S1-2209 McKean Rd

Total Coliforms (counts)			Sampling Point Name
05/04/2017 12:20	< 1	counts/100ml	S1-2209 McKean Rd

Total Dissolved Solids / TDS			Sampling Point Name
05/04/2017 12:20	123	mg/L	S1-2209 McKean Rd

Total Kjeldahl Nitrogen / TKN			Sampling Point Name
05/04/2017 12:20	0.084	mg/L	S1-2209 McKean Rd

Total Organic Carbon / TOC			Sampling Point Name
05/04/2017 12:20	2.44	mg/L	S1-2209 McKean Rd

Total Trihalomethanes / TTHM			Sampling Point Name
02/22/2017 12:42	0.0487	mg/L	S1-2209 McKean Rd
05/04/2017 12:20	0.0701	mg/L	S1-2209 McKean Rd
08/16/2017 00:00	0.0753	mg/L	S1-2209 McKean Rd
11/09/2017 09:45	0.0763	mg/L	S1-2209 McKean Rd

Trichloroacetic acid			Sampling Point Name
02/22/2017 12:42	0.0231	mg/L	S1-2209 McKean Rd
05/04/2017 12:20	0.0468	mg/L	S1-2209 McKean Rd
08/16/2017 00:00	0.0346	mg/L	S1-2209 McKean Rd
11/09/2017 09:45	0.0415	mg/L	S1-2209 McKean Rd

Turbidity			Sampling Point Name
05/04/2017 12:20	0.28	NTU	S1-2209 McKean Rd

Uranium (total)			Sampling Point Name
05/04/2017 12:20	< 0.00010	mg/L	S1-2209 McKean Rd

Vanadium (total)			Sampling Point Name
05/04/2017 12:20	< 0.030	mg/L	S1-2209 McKean Rd

Zinc (total)			Sampling Point Name
05/04/2017 12:20	0.0074	mg/L	S1-2209 McKean Rd

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, U=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

< means less than lower detection limit shown

> means greater than upper detection limit shown
« means detected & less than number shown
» means detected & greater than number shown
*** Indicates Criteria is exceeded**

CVRD

NORTH SHAWNIGAN LAKE COMMUNITY WATER SYSTEM

Facility Location:
175 Ingram Street
Shawnigan Lake

Facility Information:
Facility Type: 301-10000 DWT

Facility Sampling History:

Location	Date	Total Coliform	E.Coli
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	11-Dec-2017	L1	L1
S-7 3057 Miner Road, S-7 3057Miner Road	11-Dec-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	4-Dec-2017	L1	L1
S-5 End of Gregory Rd. Reservoir , end of Gregory Road, Shawnigan Lake, BC	4-Dec-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	28-Nov-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	20-Nov-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	14-Nov-2017	T	
S-8, Lot 10 Katy's Crescent, 10 Katy's Crescent, Shawnigan Lake, BC	14-Nov-2017	T	
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	8-Nov-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	8-Nov-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	30-Oct-2017	L1	L1
S-7 3057 Miner Road, S-7 3057Miner Road	30-Oct-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	24-Oct-2017	L1	L1
S-8, Lot 10 Katy's Crescent, 10 Katy's Crescent, Shawnigan Lake, BC	24-Oct-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	16-Oct-2017	L1	L1
S-7 3057 Miner Road, S-7 3057Miner Road	16-Oct-2017	L1	L1

S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	10-Oct-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	10-Oct-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	2-Oct-2017	L1	L1
S-5 End of Gregory Rd. Reservoir , end of Gregory Road, Shawnigan Lake, BC	2-Oct-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	25-Sep-2017	L1	L1
S-5 End of Gregory Rd. Reservoir , end of Gregory Road, Shawnigan Lake, BC	25-Sep-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	18-Sep-2017	L1	L1
S-8, Lot 10 Katy's Crescent, 10 Katy's Crescent, Shawnigan Lake, BC	18-Sep-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	11-Sep-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	11-Sep-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	5-Sep-2017	L1	L1
S-7 3057 Miner Road, S-7 3057Miner Road	5-Sep-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	29-Aug-2017	L1	L1
S-5 End of Gregory Rd. Reservoir , end of Gregory Road, Shawnigan Lake, BC	29-Aug-2017	L1	L1
S-5 End of Gregory Rd. Reservoir , end of Gregory Road, Shawnigan Lake, BC	29-Aug-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	22-Aug-2017	L1	L1
S-8, Lot 10 Katy's Crescent, 10 Katy's Crescent, Shawnigan Lake, BC	22-Aug-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	14-Aug-2017	L1	L1
S-7 3057 Miner Road, S-7 3057Miner Road	14-Aug-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	9-Aug-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	9-Aug-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	1-Aug-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	1-Aug-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	25-Jul-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	25-Jul-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	18-Jul-2017	L1	L1

S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	17-Jul-2017	L1	L1
S-7 3057 Miner Road, S-7 3057Miner Road	17-Jul-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	10-Jul-2017	L1	L1
S-8, Lot 10 Katy's Crescent, 10 Katy's Crescent, Shawnigan Lake, BC	10-Jul-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	4-Jul-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	27-Jun-2017	L1	L1
S-8, Lot 10 Katy's Crescent, 10 Katy's Crescent, Shawnigan Lake, BC	27-Jun-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	20-Jun-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	20-Jun-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	20-Jun-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	13-Jun-2017	L1	L1
S-7 3057 Miner Road, S-7 3057Miner Road	13-Jun-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	5-Jun-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	5-Jun-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	29-May-2017	L1	L1
S-8, Lot 10 Katy's Crescent, 10 Katy's Crescent, Shawnigan Lake, BC	29-May-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	24-May-2017	L1	L1
S-7 3057 Miner Road, S-7 3057Miner Road	24-May-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	15-May-2017	L1	L1
S-5 End of Gregory Rd. Reservoir , end of Gregory Road, Shawnigan Lake, BC	15-May-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	9-May-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	9-May-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	2-May-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	2-May-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	25-Apr-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	19-Apr-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	19-Apr-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	11-Apr-2017	L1	L1
S-7 3057 Miner Road, S-7 3057Miner Road	11-Apr-2017	L1	L1

S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	4-Apr-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	4-Apr-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	27-Mar-2017	L1	L1
S-5 End of Gregory Rd. Reservoir , end of Gregory Road, Shawnigan Lake, BC	27-Mar-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	21-Mar-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	14-Mar-2017	L1	L1
S-7 3057 Miner Road, S-7 3057Miner Road	14-Mar-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	7-Mar-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	7-Mar-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	28-Feb-2017	L1	L1
S-5 End of Gregory Rd. Reservoir , end of Gregory Road, Shawnigan Lake, BC	28-Feb-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	20-Feb-2017	L1	L1
S-7 3057 Miner Road, S-7 3057Miner Road	20-Feb-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	14-Feb-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	14-Feb-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	7-Feb-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	30-Jan-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	30-Jan-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	24-Jan-2017	L1	L1
S-7 3057 Miner Road, S-7 3057Miner Road	24-Jan-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	18-Jan-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	18-Jan-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	9-Jan-2017	L1	L1
S-1 2209 McKean, 2209 Mckean, Shawnigan Lake, BC	4-Jan-2017	L1	L1
S-4 2032 Sunnybrook Lane , 2032 Sunnybrook Lane, Shawnigan Lake	4-Jan-2017	L1	L1